

EXHUAUST FAN INSTALLATIONS SPECIFICATIONS & PROPOSAL

Scope of Services

Coastal Community Action, Inc., Weatherization Assistance Program is currently seeking contractors to install bath and kitchen exhaust fans in existing residential properties. Only NC licensed professionals may apply. Installations of exhaust fans shall be completed in accordance with ASHRAE 62.2-2013, NC Weatherization Assistance Program Standards and NC State and Local Code requirements.

Scope of Services

The Subcontractor agrees to provide the services as described on the Scope of Work document provided by the Contractor. Likely tasks include, but are not limited to:

1. Install bath exhaust fan that have a sone rating of 1.0 or less and have an installed and properly ducted measured airflow rate of not less than 50cfm.
2. Install proper vent ducting for bathroom exhaust fan that terminates completely outside of the dwelling
3. Install new powered circuit for bathroom exhaust fan;
4. Install programmable ventilation control switch (0-60mins/hr);
5. Install kitchen range hoods that have a sone rating of 3.0 or less and have an installed and properly vented measured airflow rate of not less than 100cfm and not greater than 200cfm.
6. Replace existing or install new (where no existing) kitchen range hood or exhaust fan;
7. Install proper vent ducting for kitchen range hood or exhaust fan that terminates completely outside of the dwelling;
8. Install new powered circuit for kitchen exhaust where none exists.